

within the space protected, the system shall be arranged in an approved manner to be automatically operated by a heat actuator within the space in addition to the regular remote and local controls.

(c) The space containing the cylinders shall be properly ventilated and designed to preclude an anticipated ambient temperature in excess of 130 degrees F.

(d) Cylinders shall be securely fastened and supported, and, where necessary, protected against injury.

(e) Cylinders shall be so mounted as to be readily accessible and capable of easy removal for recharging and inspection. Provisions shall be available for weighing the cylinders.

(f) Where subject to moisture, cylinders shall be so installed as to provide a space of at least 2 inches between the flooring and the bottom of the cylinders.

(g) Cylinders shall be mounted in an upright position or inclined not more than 30 degrees from the vertical. However, cylinders which are fitted with flexible or bent syphon tubes may be inclined not more than 80 degrees from the vertical.

(h) Where check valves are not fitted on each independent cylinder discharge, plugs or caps shall be provided for closing outlets when cylinders are removed for inspection or refilling.

(i) All cylinders used for storing carbon dioxide must be fabricated, tested, and marked in accordance with §§ 147.60 and 147.65 of this chapter.

[CGFR 65-50, 30 FR 16940, Dec. 30, 1965, as amended by CGD 84-044, 53 FR 7748, Mar. 10, 1988; USCG-1999-6216, 64 FR 53226, Oct. 1, 1999]

§ 76.15-25 Discharge outlets.

(a) Discharge outlets shall be of an approved type.

(b) [Reserved]

§ 76.15-30 Alarms.

(a) Spaces which are protected by a carbon dioxide extinguishing system and are normally accessible to persons on board while the vessel is being navigated, other than paint and lamp lockers and similar small spaces, shall be fitted with an approved audible alarm in such spaces which will be automatically sounded when the carbon dioxide

is admitted to the space. The alarm shall be conspicuously and centrally located and shall be marked as required by § 78.47-9 of this subchapter. For systems installed on or after July 1, 1957, alarms will be mandatory only for systems required to be fitted with a delayed discharge. Such alarms shall be so arranged as to sound during the 20 second delay period prior to the discharge of carbon dioxide into the space, and the alarm shall depend on no source of power other than the carbon dioxide.

(b) [Reserved]

§ 76.15-35 Enclosure openings.

(a) Where mechanical ventilation is provided for spaces other than cargo and similar spaces which are protected by a carbon dioxide extinguishing system, provisions shall be made so that the ventilation system is automatically shut down with the operation of the system to that space.

(b) Where natural ventilation is provided for spaces protected by a carbon dioxide extinguishing system, provisions shall be made for easily and effectively closing off the ventilation.

(c) Means shall be provided for closing all openings to the space protected from outside such space. In this respect, relatively tight doors, shutters, or dampers shall be provided for openings in the lower portion of the space. The construction shall be such that openings in the upper portion of the space can be closed off either by permanently installed means or by the use of canvas or other material which is normally carried by the vessel.

§ 76.15-40 Pressure relief.

(a) Where necessary, relatively tight compartments such as refrigeration spaces, paint lockers, etc., shall be provided with suitable means for relieving excessive pressure accumulating within the compartment when the carbon dioxide is injected.

(b) [Reserved]

[CGFR 65-50, 30 FR 16940, Dec. 30, 1965, as amended by CGFR 66-33, 31 FR 15283, Dec. 6, 1966]